



Product Certification Body accredited
by Slovak national accreditation service



APPROVED BODY No. SK01
Osloboditeľov 282, 059 35 Batizovce, Slovensko
tel. +421 52 7752298 fax. +421 52 7881412 e-mail: info@fires.sk http://www.fires.sk



SK – CONFORMITY CERTIFICATE

SK01 – ZSV – 0122

In accordance with law No. 90/1998 Z. z. about building products as amended by subsequent provisions and regulation of Ministry of Construction and Regional Development of the Slovak Republic No. 158/2004 Z.z. which group of construction products with dedicated conformity attestation systems and details of conformity marks usage are stated by in wording of regulation No. 119/2006 Z. z., this is to certify, that

Fire resistant Air Transfer Grille, type IMOS – PVM, type IMOS - PVM with servo-drive

launched on the market by the manufacturer

IMOS-Systemair, s.r.o., Kalinkovo 146, 900 43 Kalinkovo, Slovakia

and made by the manufacturer

IMOS-Systemair, s.r.o., Kalinkovo 146, 900 43 Kalinkovo, Slovakia

is submitted by manufacturer to the factory production control and planned tests of product specimens taken off in workshop in accordance with specified plan of tests and approved body FIRES s.r.o. carried out initial type tests of product properties, initial inspection of workshop and factory production control and is carrying out continuous inspection, evaluation and approval of the factory production control.

By this certificate, it is confirmed that all provisions of law § 8, Law of National Council of the Slovak Republic No. 163/2001 Coll., regulation of Ministry of Interior of the Slovak Republic No. 94/2004 Coll. and standard STN 74 6481: 2000, STN 74 6481: 2000/Z1: 2003 and STN 74 6481: 2000/ Z2: 2006

related to the factory production control and product properties stated at certification seemy side, which have influence on the pursuance of main requirements to buildings are applied and product is up to all specified standards.

The certificate issued on 14. 02. 2007 for the first time remains of force until conditions stated by mentioned standards or manufacturing conditions at the workshop or factory production control are without significant changes.

Batizovce, 04. 10. 2007



-1-

Ing. Mária Gašperová
Head of Product Certification Body

014481

Approved body No. SK01 certifies conformity of properties:

reaction to fire/ type of construction, fire resistance, automatic closing in case of fire, emission of dangerous substances to environment, corrosion resistance

which have influence on the pursuance of main requirements for buildings and product is up to all specified standards.

Conformity attestation of individual properties is stated in the Initial type testing report of constructional product No.C01/06/0047/2801/SC issued by Fires, s.r.o., Batizovce, Slovakia on 14. 02. 2007.

Product is used according following conditions

- fire resistance of Air Transfer Grille, type IMOS-PVM is E 120; EI₁ 90; EI₂ 120; EW 60;
- fire resistance of Air Transfer Grille, type IMOS-PVM with servo-drive is E 120; EI₁ 60; EI₂ 120; EW 60;
- Air Transfer Grille, type IMOS-PVM has to be automatically closed till 114 seconds from fire commencement;
- Air Transfer Grille, type IMOS-PVM with servo-drive has to be automatically closed till 40 seconds from fire commencement;
- conditions stated in the classification report No. FIRES-CR-021-07-AUPS, issued by FIRES, s.r.o., Batizovce, on 09. 02. 2007 must be fulfilled.



on 04th October 2007 in Batizovce


Ing. Mária Gašperová
Head of Product Certification Body