

## Mechanical ventilation



Type	Index number	Status
Centralised MEV and MVHR systems	500407	Normal
Brand	Model name	Model qualifier
Systemair	SAVE VTC 200 L	Ver A
System type	balanced whole-house mechanical ventilation with heat recovery	
Duct type	rigid	
Minimum duct size	125 mm diameter or 204 x 60 rectangular or larger	
Original manufacturer name	Systemair Fans & Spares Ltd	
Current manufacturer name	Systemair Fans & Spares Ltd	
Manufacturer address	Avenue 2 Station Lane Industrial Estate Witney Oxfordshire OX28 4YL	
Manufacturer phone	01993 778481	
Manufacturer website	<a href="http://www.villavent.co.uk">www.villavent.co.uk</a>	
First year of manufacture	2014	
Final year of manufacture	current	
Summer bypass	yes	
Integrated to exhaust air heat pump	No	
Entry updated	03/12/2014 12:00	

K+n wet rooms	SFP (W/l/s) [2009]	Efficiency (%) [2009]	SFP (W/l/s) [2012]	Efficiency (%) [2012]
n = 1	0.82	89%	0.73	89%
n = 2	0.74	89%	0.75	89%
n = 3	0.74	89%	0.81	89%
n = 4	0.78	89%	0.97	88%
n = 5	0.84	88%	1.14	88%
n = 6	0.96	88%	-	-
n = 7	1.08	88%	-	-

Delivered by 