

## Mechanical ventilation



Type	Index number	Status
Centralised MEV and MVHR systems	500216	Normal
Brand	Model name	Model qualifier
Villavent	VR 300 ECV / B	
System type	balanced whole-house mechanical ventilation with heat recovery	
Duct type	rigid	
Minimum duct size	125 mm diameter or 204 x 60 rectangular or larger	
Original manufacturer name	Villavent Ltd	
Current manufacturer name	Systemair Fans & Spares Ltd	
Manufacturer address	Avenue 2 Station Lane Industrial Estate Witney Oxfordshire OX28 4YL	
Manufacturer phone	01993 778481	
Manufacturer website	<a href="http://www.villavent.co.uk">www.villavent.co.uk</a>	
First year of manufacture	2010	
Final year of manufacture	current	
Summer bypass	unknown	
Integrated to exhaust air heat pump	No	
Entry updated	24/07/2012 09:02	

K+n wet rooms	SFP (W/l/s) [2009]	Efficiency (%) [2009]	SFP (W/l/s) [2012]	Efficiency (%) [2012]
n = 1	1.73	77%	1.77	79%
n = 2	1.69	80%	1.74	80%
n = 3	1.69	80%	1.72	80%
n = 4	1.66	81%	-	-

Delivered by 